

STYLE 4530* & 4535* ASSAULT FLOW KITS

| 4530-4004 | 150 GPM @ 50 PSI | 4530-4011 | 360 LPM @ 700 KPA |
|------------------|-------------------|------------------|-------------------|
| 4530-4005 | 161 GPM @ 50 PSI | 4535-4004 | 250 GPM @ 50 PSI |
| 4530-4006 | 175 GPM @ 50 PSI | 4535-4002 | 200 GPM @ 75 PSI |
| 4530-4007 | 185 GPM @ 50 PSI | 4535-4001 | 250 GPM @ 75 PSI |
| 4530-4001 | 95 GPM @ 75 PSI | 4535-4003 | 300 GPM @ 75 PSI |
| 4530-4008 | 125 GPM @ 75 PSI | 4530-7002 | 150 GPM @ 50 PSI |
| 4530-4003 | 150 GPM @ 75 PSI | □ 4530-7001 | 95 GPM @ 75 PSI |
| 4530-4009 | 175 GPM @ 75 PSI | 4530-7003 | 125 GPM @ 75 PSI |
| 4530-4010 | 200 GPM @ 75 PSI | 4530-7007 | 175 GPM @ 75 PSI |
| 4530-4002 | 95 GPM @ 100 PSI | 4530-7004 | 125 GPM @ 100 PSI |
| 4530-4012 | 570 LPM @ 350 KPA | 4530-7005 | 570 LPM @ 350 KPA |
| 4530-4013 | 550 LPM @ 500 KPA | □ 4530-7006 | 550 LPM @ 500 KPA |

INSTALLATION INSTRUCTIONS

This flow kit is designed to allow you to convert your Assault nozzle to a different flow rate. The conversion instructions must be followed in order to assure the Assault achieves the flow indicated on the baffle.

IMPORTANT – Each nozzle has color-coded metal flow spacer(s) under the baffle head and may have plastic adjustment shim(s). The plastic adjustment shim must be used with the conversion baffle.

- 1. Remove the screw that secures the baffle head. Caution: Be careful not to lose flow spacer(s) and adjustment shim(s).
- 2. Remove the baffle head, flow spacer(s) and adjustment shim(s).
- 3. Remove the plastic thread cap from the new baffle screw.
- 4. Take the plastic adjustment shim(s) from the original baffle assembly and place it between the new baffle head and the new flow spacer(s).
- 5. Install the new baffle assembly onto your Assault nozzle. Be sure the screw is securely hand tightened.
- 6. Flow test the nozzle to be sure it is operating properly.

If any problems are encountered or questions arise, contact Akron Brass Customer Service at (800) 288-1161.

*Note: Style 4530-4xxx kits fit 4863/4866 nozzles. Style 4535-4xxx kits fit 4824/4826 nozzles. Style 4530-7xxx kits fit 4820/4815 nozzles.

WARRANTY AND DISCLAIMER*: We warrant Akron Brass products for a period of five (5) years* after purchase against defects in materials or workmanship. Akron Brass will repair or replace product which fails to satisfy this warranty. Repair or replacement shall be at the discretion of Akron Brass. Products must be promptly returned to Akron Brass for warranty service. We will not be responsible for: wear and tear, any improper installation, use, maintenance or storage; negligence of the owner or user; repair or modification after delivery; failure to follow our instructions or recommendations; or anything else beyond our control. WE MAKE NO WARRANTIES, EXPRESS OR IMPLIED, OTHER THAN THOSE INCLUDED IN THIS WARRANTY STATEMENT, AND WE DISCLAIM ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE. Further, we will not be responsible for any consequential, incidental or indirect damages (including, but not limited to, any loss of profits) from any cause whatsoever. No person has authority to change this warranty. Unless otherwise provided herein. Akron Brass industrial electronic components & the Severe-Duty Monitor have a one (1) year warranty. Select Akron Brass handline nozzles and valves carry a ten (10) year warranty. Weldon products have a two (2) year warranty from date of manufacture (excluding consumable components). Select Weldon LED products carry a five (5) year warranty. Honda products have the manufacturers' warranty and Akron Brass disclaims any warranty in respect of those products.

PHONE: 800.228.1161 | WEBSITE: www.akronbrass.com

Sheet: 128269 Revision: 2/21 Page: 1 of 1